

HEPA TEST REPORT LMS Technologies, Inc.

6423 Cecilia Circle
Bloomington, MN 55439

Tel: (952)918-9060
Fax: (952)918-9061

Test Type:	HEPA Test	Test Requested By:	Alexapure, LLC
Test Number:	T122216A	Media Manufacturer:	N/A
Flow Rate/Velocity:	131 CFM	Filter Manufacturer:	Alexapure, LLC
Test Aerosol:	KCl, Neutralized	Filter ID Number:	HEPA Filter AP-B103
Filter Size:	14.25"x11"x1.375" (HxWxD)	Filter Description:	White Pleated Filter

Flow Rate (cfm)	ΔP ("H ₂ O)	Size Range (μm)	Fractional Efficiency (%)
32.8	0.047	0.3-0.5	99.999
65.5	0.095	0.5-0.7	100.000
98.2	0.146	0.7-1.0	100.000
131.0	0.198	1.0-2.0	100.000
163.8	0.251	2.0-3.0	100.000
		3.0-5.0	100.000
		>5.0	100.000



Data verified by LMS Calibration Filter* Patent Pending

